



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE200306006867

Product

Automatic Transfer Switching Equipment

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGQ1NP-125;

Technical data

Ue:AC230V(2P),AC400V(3P,4P);Ie:16A,20A,25A,32A,40A,50A,
63A,80A,100A,125A;Ui:800V;Uimp:8kV(main),
2,5kV(control);Ith:125A;Icm(peak value):17kA;
Icw:10kA/30ms;Utilization category: AC-33B;Class of
equipment: PC; Method of controlling: ATSE; Pole:2P,3P,4P

This is to certify that, on the basis of the tests undertaken as per Report No.
CE-045-1C200259, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Jul.27,2020

Valid until: Jul.27,2023

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>