



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE160305005128-A1

Product

AC contactor

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGC1-06,TGC1-06N,TGCG-06,TGCG-06N,TGCJH-06,TG
CJH-06N;

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
02401-1911904509, the submitted sample(s) of the above item complies with:

EN 60947-4-1:2010 + A1:2012

and fulfills testing requirements of the European Directive:

2014/35/EU

Valid from: Aug.29,2019

Valid until: Aug.29,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE

CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE160305005128-A1

TGC1-06,TGC1-06N,TGCG-06,TGCG-06N,TGCJH-06,TGCJH-06N;

Ui:690V;

Uimp:6kV;number of poles:3P;

Ith: TGC1-06,TGC1-06N,TGCG-06,TGCG-06N,TGCJH-06,

TGCJH-06N:16A;

utilization category:AC-1,AC-3,AC-4;IP20

Ue:AC220V/230V,AC380V/400V,AC660V/690V;

TGC1-06,TGCG-06,TGCJH-06:Ie:6A(220V/230V;AC-3),

6A(380V/400V;AC-3),3.8A(660V/690V;AC-3),

2.6A(220V/230V;AC-4),2.6A(380V/400V;AC-4),

1A(660V/690V;AC-4),6A (220V/230V;380V/400V;AC-1) ;

TGC1-06N,TGCG-06N,TGCJH-06N:Ie:2.6A(220V/230V;AC-4) ,

2.6A(380V/400V;AC-4) ,1A(660V/690V;AC-4),

6A (220V/230V;380V/400V;AC-1)

Us:AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,

AC415V,50Hz;

Us:AC24V,AC36V,AC48V,AC110V,AC220V,AC380V,AC400V,

AC415V,50/60Hz;

Auxiliary Circuits:

1NO,1NC;Ith:10A;

AC-15:Ue/Ie:AC220V/1.6A, AC380V/0.95A;

DC-13:Ue/Ie:DC220V/0.15A

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>