



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE180302005835-H1

Product

Switch Capacitor Contactor

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGCC1-25

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
(2018)FQIIDQCE-0154-H1, the submitted sample(s) of the above item complies with:

EN 60947-4-1:2010 + A1:2012

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jun.03,2021

Valid until: Jun.03,2024

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE180302005835-H1

TGCC1-25

Uimp:6kV

Ui:690V

Ith:25A;

Ue:AC220V/230V,AC380V/400V,AC660V/690V;

Ie:17A;

AC-6b;

Us:AC110V,AC220V,AC380V,AC400V,AC415V,50Hz;

AC110V,AC220V,AC380V,AC400V,AC415V,50/60Hz;

Qe:7kvar(220V/230V),12kvar(380V/400V),18kvar(660V/690V);3P;IP20;

Matching auxiliary contact:

Ith:10A

AC-15:AC380V/0.95A

DC-13:DC220V/0.15A

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>