



CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Certificate No.: CE210305007285

Product

Contactor for Capacitor Switching

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGCC1-95

Technical data

See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No.
(2021)FQIIDQCE-0227, the submitted sample(s) of the above item complies with:

EN 60947-4-1:2010 + A1:2012

and fulfills testing requirements of the European Directive:

Low Voltage Directive (LVD): 2014/35/EU

This report is to verify the compliance of the sample submitted by the manufacturer only,
and does not include the manufacturing process. Users shall affix the mark in accordance
with the related legislation.

Valid from: Jul.05,2021

Valid until: Jul.05,2024

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



CHINA QUALITY CERTIFICATION CENTRE





CHINA QUALITY CERTIFICATION CENTRE CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE210305007285

TGCC1-95

Uimp:6kV,Ui:690V;lth:95A;

Ue:AC220V/230V,AC380V/400V,AC660V/690V;

Ie:73A;

Utilization category:AC-6b;

Us:AC110V,AC220V,AC380V,AC400V,AC415V,50Hz;

AC110V,AC220V,AC380V,AC400V,AC415V,50/60Hz;

Qe:35kvar(220V/230V),50kvar(380V/400V),92kvar(660V/690V);

3P;IP20;

Matching auxiliary contact:lth:10A, 1NO1NC;

(Switch contactor)lth:10A,1NO,1NC

AC-15:380V/0.95A,DC-13:220V/0.15A



CHINA QUALITY CERTIFICATION CENTRE

