



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190303006475

Product

Moulded Case Circuit-Breaker

Applicant

Zhejiang Tengen Electric Co.,Ltd.

Sulv Industrial Area, Liushi Town, Yueqing City, Zhejiang
Province, P.R.China

Type/Model

TGM1N-800L/M/H

Technical data

See Annex

This is to certify that, on the basis of the tests undertaken as per Report No.
00901-CE2017CQC0303-008658, the submitted sample(s) of the above item complies
with:

EN 60947-2:2006 + A1:2009 + A2:2013

and fulfills testing requirements of the European Directive:

2014/34/EU

Valid from: Oct.10,2019

Valid until: Oct.10,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0009746



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 2

Certificate No.: CE190303006475

Annex :

TGM1N-800L/M/H

Ui:1000V

Uimp:12kV

Ue:AC380/400/415V, AC660/690V

In:630A,700A,800A

Over-current release: thermo-magnetic

Ics: AC380/400/415V: 35kA(L type), 50kA(M type), 75kA(H type)

AC660/690V: 15kA(L type), 15kA(M type), 15kA(H type)

Icu: AC380/400/415V: 50kA(L type), 70kA(M type), 100kA(H type)

AC660/690V: 15kA(L type), 20kA(M type), 20kA(H type)

Selectivity category:A

50/60Hz

Poles: 3P,3P+N(3 protected poles with an uninterrupted neutral pole),4P(3 protected poles with a switched neutral pole),4P

IP20

Suitable for insulation(except for 3P+N);

Auxiliary and alarm contacts:

Type:OF-M,SD-M

1NO1NC, 2NO2NC,4NO4NC

Ith:6A

AC-15:AC380/400/415V 1A

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 2 of 2

Certificate No.: CE190303006475

DC-13:DC110/220/250V 0,15A

Accessories with electronic circuits:

Motor operator (CD2): AC220/230/240V, AC380/400/415V

Pre-paid shunt release (FT): AC220/230/240V, AC380/400/415V

Undervoltage release(QT): AC220/230/240V, AC380/400/415V

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>